Facility Name Goodnews Bay									
Inspector JBlitz/DEvans/			JBright/BKirk			DATE 5/24/2018			
#		Item	PASS	FAIL	Comm	ents	Initial		
1	Housekeeping		Р	F	Wood d	debris			
2	Safety								
2a	Fire extinguishers Adequate, accessible, charged		Р	F					
2b	Signage: NOT SMOKING Posted and visible		Р	F					
2c	Signage: DANGER & WARNING Posted and visible		Р	\					
3	Segurity								
3a	Fencing Intact and locked		P	F	•				
3b	Lightning Adequate and functioning		Р	T.	No lighting				
4	Storage Tanks								
4a	Soundnes No visible le		P	F					
4b	Corrosion Protection No signs of rusting or corrosion		Р	1	Pair	nt chipping			
4c	Signage product, capacity, hazard rating		P	F					
4d	Vents Clear		P	F					
4e	Paint No peeling	or cracking	Р	F	Paint	chipping			
4f	Foundations Solid, no cracks or rotting		Р		Old				
4g		nd overfill devices st overfill alarms	Р	F	Not p	resent			
5	Piping and Hoses								
5a	Soundnes No visible le cracking	ss eakage, dips, or	P	F	Supporte	d but unse	cured		
5b		Protection rusting or corrosion	Р		Piping rus	sted			

5c	Supports Adequate and intact	P		Supported but unsecured				
5d	Nozzles No visible leakage, working	Р	F					
5e	Valves No visible leakage, working	P	F					
5f	Protection From falling snow, ice, and traffic	Р	F					
5g	Coating, Wrapping and Paint Wear, tear, and chipping	Р	F					
6	Secondary Containment							
6a	Size adequate	Р						
6b	Clear No standing water, snow, ice or vegetation	Р	L I	11				
6c	Liner Soundness Free of rips, tears, non essential penetrations	Р	F	No liner				
7	Spill Prevention and Response							
7a	Response Plan Located at facility	Р	E					
7b	Response Equipment Adequate, located on site	Р	F					
8	Government Requirements							
8a	ADEC Spill notification placard where it can be seen	P	F					
8b	USEPA FRP current and on site	Р	F					
8c	USCG Letter of intent to operate, operations manual, SPCC available	Р	F					
9	Miscellaneous							